

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0026:217 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Simplex, *100 Simplex Drive, Westminster, MA 01441-0001
Contact: Paul Mattern (978) 731-8542

DESIGN: Models 4098-9789, 4098-9789E, 4098-9791, 4098-9791E, 4098-9792, 4098-9792E, 4098-9793, 4098-9793E, 4098-9794, 4098-9795 and 4098-9796 detector bases. The base acts as an interface between the sensor and the MAPNET controller. Units are intended for use with Models 4098-9714 and 4098-9754 smoke detector (CSFM Listing No. 7272-0026:218), 4098-9717 smoke detector (CSFM Listing No. 7271-0026:231) and 4098-9733 heat detector (CSFM Listing No. 7270-0026:216). Models 4098-9795 and 4098-9796 are only intended for use with model 4098-9754 smoke detector. Refer to listee's printed data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as detector bases for use with listee's separately listed compatible fire alarm control units.

Models 4098-9794 and 4098-9795 employ a sounder, which also suitable for use as fire alarm audible signaling device. These base/sounders can not produce the temporal code pattern in accordance with NFPA 72, 1996 Edition. If this temporal code is required, the sounder/base unit must be used with the control unit that can produce the temporal pattern. Refer to listee's Installation Instructions Manual for additional information.

*Rev. 06-21-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**